

RCM Sections Update

Division 03 – Concrete

Section 03300 – Cast-In-Place Concrete (Short Section)

Submittal 02 Shop Drawings

Delete “Installation” from beginning of submittal.

Add “Concrete Placement Plan,” insert the word “Plan.”

Submittal Addition

Submittal SD-03 Product Data

Curing Compound

Waterstops

Air-Entraining Admixtures

Chemical Hardener

Steel Reinforcement

Fly Ash

Ready Mix Concrete

Submittal SD-07 Certificates

Delete entire submittal; redundant information. No added value.

Article 1.4 Installation Drawings

Replace “Installation” in article heading with the word “Shop.”

Remove brackets from around **Concrete Placement, Steel Reinforcement, and Accessories;** add commas.

Delete “**Forms**” from article.

Article 2.4 Accessories

Correct numbering of article to **2.4** from **2.2**.

Article 2.4.2 Chemical Floor Hardener

Delete “**Floor**” from article heading.

Identify if ASTM used by other agency exists. If so, add to **2.4.2** and **3.9**. Otherwise, Identify ASTM and add to both article.

Article 3.9 Chemical-Hardener Treatment

Delete “floor” from first sentence of article, “Liquid-chemical hardener shall be...”

Article 3.11 Field Testing

Rewrite article to read, “[**Slump, Air-Entrainment, and Concrete Temperature** shall be tested on site for each design mix, according to ASTM C 143.] Delete [plant] from article.